



1

Accredited by BMWA, number GZ 92714/237-IV/9/00

Test Report

Project Designation

Test of fuse bases
type PK, PKI, PP, PPI and PPR

Client

ELEKTROELEMENT d.d.
1411 Izlake, Obrezija 5
SLOVENIA

Order from / No

08.06.2001 / -

Project number

2.03.00021.1.0/BASE

Test Engineer

Ing.J.Ainetter

Date of issue	25.06.2001
Total number of issues / No	1 / 1
Number of pages	5
Annex: number of pages	-

The results relate exclusively to the terms tested.

This report may only be reproduced or published in full, without omissions, alterations or additions.

The reproduction or publishing of extracts from this report require the written approval of the research center.

Test item

Identification:

Fuse base

⇒ PK

⇒ PKI

⇒ PP

⇒ PPI

⇒ PPR

Rated voltage: 690VAC

Rated current: 125A to 1250A

Manufacturer:

As client

Technical data:

See page 3 to 5

Testing location, Period of testing

Testing location:

ÖFPZ Arsenal Ges.m.b.H.

Monitoring, Energy and Drive Technologies

Period of testing:

2001

Test(s)

Test(s) performed:

Type tests at fuse-links in use with appropriate fuse bases mentioned above

Test standard(s):

EN 60269-1:98


EN 60269-2:95 + A1:97

HD 630.2.1 S2:97

Result


We confirm, that all type tests at fuse-links were performed with appropriate fuse base PK, PKI, PP, PPI and PPR. During these tests, there was no fault caused by the fuse t

Test engineer



Ing. J. Ainetter

Project Engineer,
Technical responsibility



Ing. K. Farthofer

