**OVE Austrian Electrotechnical Association** Eschenbachgasse 9 | 1010 Wien | Austria ZVR: 327279890 | www.ove.at

**OVE Certification** Kahlenberger Str. 2A | 1190 Wien | Austria T +43 1 370 58 06 | certification@ove.at

Validity of ÖVE-Certificates can be checked at www.ove.at



Page 1 of 4



including the entitlement to use the Austrian Safety Mark



Certificate No.: 14262-067-00

Valid from: 2021 05 26 until: 2023 05 26

The Austrian Electrotechnical Association (OVE) hereby grants the right to the company mentioned below to label the listed products with the Austrian Safety Mark.

Company: ETI Elektroelement d.o.o. Obrezija 5 1411 Izlake Slovenia

Product: Residual current operated circuit-breakers without integral overcurrent protection (RCCBs)

The products submitted by the applicant were type tested in accordance with the requirements of the technical standards and specifications listed in this certificate. OVE certifies the conformity of the listed products and those products manufactured strictly identical to the submitted ones (EN ISO/IEC 17067, Conformity Assessment Scheme Type 5).

The manufacturing process and the products are subject to ongoing surveillance based on harmonized European procedures. This certificate has been issued under the presumption and conditional on the fact that the applicant holds all necessary legal rights with regard to the product, presented for the testing and certification.

Results of testing are shown in file No(s).: SGP-20240/ETI/EFI-P4+EFI-P4R

Österreichischer Verband für Elektrotechnik

Head of OVE Certification T. Neumayer Digitally signed by T. Neumayer Email=t neumayer@ove.at Digitally signed by T. Neumayer

Dipl.-Ing. T. Neumayer

Wien, 2021 05 26



**OVE Certification** 

roducts ierung.



Certificate No.: 14262-067-00 Date: 2021 05 26 Page 2 of 4

### Manufacturer:

ETI Elektroelement d.o.o. Obrezija 5 1411 Izlake Slovenia

## Factory location(s):

ETI Elektroelement d.o.o. Obrezija 5 1411 Izlake Slovenia

## Tested and certified according to:


OVE EN 61008-1:2018-04-01 ÖVE EN 61008-2-1+A11:1998-06

This certificate is the basis for the EU Declaration of Conformity and the CE Marking by the manufacturer or his agent and shows the conformity of the certified product(s) with the listed standards as defined by the **EU Low-Voltage Directive 2014/35/EU**. For the presumption of conformity according to Art. 12 with the safety objectives according to Art. 3 of the Directive, transitional periods given in the Official Journal of the European Union have to be observed.

# Product: Residual current operated circuit-breakers without integral overcurrent protection (RCCBs)

<b>Type designation:</b> Rating:	Trademark:
Series EFI-P4 Rated voltage: AC 400 V / AC 415 V Rated frequency: 50/60 Hz Rated current: 16 A, 25 A, 40 A, 63 A; $I\Delta n: 0,03 A / 0,1 A / 0,3 A / 0,5 A$ 3P+N, Inc = 10 kA, type A, AC has a handle without reset position see type list	ETI
Series EFI-P4R Rated voltage: AC 400 V / AC 415 V Rated frequency: 50/60 Hz Rated current: 16 A, 25 A, 40 A, 63 A; $I\Delta n: 0,03 A / 0,1 A / 0,3 A / 0,5 A$ 3P+N, Inc = 10 kA, type A has a handle with reset position see type list	ETI

#### **OVE** Certification







### Series EFI-P4

Rated current	Rated I∆n	Rated I∆n ETI Code number	
[A]	[A]	Туре А	Type AC
		•	
16	0,03	002061510	002061610
25	0,03	002061511	002061611
40	0,03	002061512	002061612
63	0,03	002061513	002061613
16	0,1	002061520	002061620
25	0,1	002061521	002061621
40	0,1	002061522	002061622
63	0,1	002061523	002061623
16	0,3	002061530	002061630
25	0,3	002061531	002061631
40	0,3	002061532	002061632
63	0,3	002061533	002061633
16	0,5	002061540	002061640
25	0,5	002061541	002061641
40	0,5	002061542	002061642
63	0,5	002061543	002061643





### Series EFI-P4R

Rated current	Rated I∆n	ETI Code number	
[A]	[A] [A]	Туре А	
16	0,03	002061860	
25	0,03	002061861	
40	0,03	002061862	
63	0,03	002061863	
16	0,1	002061870	
25	0,1	002061871	
40	0,1	002061872	
63	0,1	002061873	
16	0,3	002061880	
25	0,3	002061881	
40	0,3	002061882	
63	0,3	002061883	
16	0,5	002061890	
25	0,5	002061891	
40	0,5	002061892	
63	0,5	002061893	

