OVE Austrian Electrotechnical Association

Eschenbachgasse 9 | 1010 Wien | Austria ZVR: 327279890 | www.ove.at

OVE Testing and Certification

Kahlenberger Str. 2A | 1190 Wien | Austria T +43 1 370 58 06 | certification@ove.at

Validity of ÖVE-Certificates can be checked at www.ove.at



Page 1 of 3

ÖVE-CERTIFICATE

including the entitlement to use the Austrian Safety Mark



Certificate No.: 14262-008-12 Valid from: 2020 12 05

until: 2022 12 05

The Austrian Electrotechnical Association (OVE) hereby grants the right to the company mentioned below to label the listed products with the Austrian Safety Mark.

Company: ETI Elektroelement d.o.o.

Obrezija 5 1411 Izlake Slovenia

Product: Low-Voltage Fuse-Link

The products submitted by the applicant were type tested in accordance with the requirements of the technical standards and specifications listed in this certificate. OVE certifies the conformity of the listed products and those products manufactured strictly identical to the submitted ones (EN ISO/IEC 17067, Conformity Assessment Scheme Type 5).

The manufacturing process and the products are subject to ongoing surveillance based on harmonized European procedures. This certificate has been issued under the presumption and conditional on the fact that the applicant holds all necessary legal rights with regard to the product, presented for the testing and certification.

Results of testing are shown in file No(s).: 10063/ETI-DO1

Österreichischer Verband für Elektrotechnik


Head of Testing and Certification

Digitally signed by W. Martin Email=w.martin@ove.at

Dipl.-Ing. W. Martin

Wien, 2020 11 06







OVE



Certificate No.: 14262-008-12

Date: 2020 11 06 Page 2 of 3

Manufacturer:

ETI Elektroelement d.o.o. Obrezija 5 1411 Izlake Slovenia

Factory location(s):

ETI Polam Sp. z.o.o. ul. Jana Pawla II 18 06-100 Pultusk Poland

Type designation:

Tested and certified according to:

ÖVE/ÖNORM EN 60269-1:2015-06-01 ÖVE/ÖNORM E 8669-3:2014-11-01

This certificate is the basis for the EU Declaration of Conformity and the CE Marking by the manufacturer or his agent and shows the conformity with the listed standards as defined by the **EU Low-Voltage Directive 2014/35/EU**.

Tradomark.

Product: Low-Voltage Fuse-Link

Rating:	Trademark.	
DO 1 Rated voltage: AC 400 V; DC 250 V Rated current: 2 A Betriebsklasse : gG	ETI	
DO 1 Rated voltage: AC 400 V; DC 250 V Rated current: 4 A Betriebsklasse : gG	ETI	
DO 1 Rated voltage: AC 400 V; DC 250 V Rated current: 6 A Betriebsklasse: gG	ETI	
DO 1 Rated voltage: AC 400 V; DC 250 V	ETI	

OVE Testing and Certification

Rated current: 10 A Betriebsklasse : gG





Certificate No.: 14262-008-12

Date: 2020 11 06

Page 3 of 3

DO 1 ETI

Rated voltage: AC 400 V; DC 250 V

Rated current: 13 A Betriebsklasse: gG

DO 1 ETI

Rated voltage: AC 400 V; DC 250 V

Rated current: 16 A Betriebsklasse : gG



